

c/o Opta Information Intelligence

June 27, 2023

RECOGNITION FOR FIRE INSURANCE GRADING RECEIVED

Tay Township Fire Department Superior Tanker Shuttle Service - Accredited

I am pleased to advise you that the above-mentioned fire protection district within the province of Ontario was recently registered in the fire insurance grading index as being accredited for the delivery of Superior Tanker Shuttle Service.

The requirements for this accreditation are stringent and verify that the fire protection district is capable of delivering the minimum <u>accepted</u> fire flows to detached dwellings throughout the fire protection district and within 8 kilometres by road of the responding fire station. This accreditation is an <u>equivalency</u> to the minimum requirements for hydrant protection as set out by the insurance industry and the Fire Underwriters Survey.

Fire Underwriters Survey has provided information on fire protection and risk levels to the insurance industry in Canada since 1883. Fire Underwriters Survey was previously operated under the auspices of the Insurers Advisory Organization, CGI; however, is now operated by Opta Information Intelligence.

Should you have any questions or concerns related to the Fire Underwriters Survey, the Superior Tanker Shuttle Service Accreditation process or any other related area, please contact the offices of Fire Underwriters Survey for further information.

Please note that this accreditation expires on June 27, 2028 and is valid for the following fire station:

- Fire Station 1 Fallowfield Lane Waubaushene
- Fire Station 2 2201 Old Fort Road, Tay
- Fire Station 4 714 Third Avenue, Port McNicoll
- Fire Station 5 266 Park Street, Victoria Harbour

The above noted fire station(s) operated by Tay Township Fire Department achieved a fire flow rate of 243 Igpm (1105 LPM).

Robert Aguiar, C.Tech Director, Ontario/Atlantic Fire Underwriters Survey

